

OMNITRAFIC 43
le et dalle

objectflor[®]
Your Flooring Partner



British Carpet Technical Centre
Wira House
West Park Ring Road
Leeds, LS16 6QL
England

Tel: +44 (0)113 259 1999
Fax: +44 (0)113 278 0306
Web: <http://www.bttg.co.uk>
Email: CSLeeds@bttg.co.uk

1 Introduction

This classification report defines the classification assigned to Polyflor 2000 PUR / Primus 2000 PUR / Voyager PUR (as described by the sponsor) in accordance with the procedures given in EN 13501-1:2007+A1:2009.

CLASSIFICATION OF REACTION TO FIRE IN ACCORDANCE WITH BS EN 13501-1:2007+A1:2009

Sponsor: Polyflor Limited
Prepared by: BTTG Testing & Certification Ltd
Product name: Polyflor 2000 PUR / Primus 2000 PUR / Voyager PUR
Classification report no.: 26/01900C/7/15 (Classification)
Issue number: 1
Date of issue: 24 July 2015

This classification report consists of four pages and may only be used or reproduced in its entirety.

BTTG Testing & Certification Ltd Registered Office:
Unit 14, Wheel Forge Way, Trafford Park, Manchester M17 1EH.
A company registered in England & Wales with company number 04669650 VAT Number GB 816740526
Our laboratories are accredited to EN ISO/IEC 17025



1066

James Halstead France SAS

Parc St Christophe – Pôle Edison 1

95861 Cergy Pontoise - Tel: 08 20 20 32 11

Edition : 05/17 – N°PRIM04128

James Halstead
FLOORING

POLYFLOR
COVERING THE WORLD



British Carpet Technical Centre
Wira House
West Park Ring Road
Leeds, LS16 6QL
England

Tel: +44 (0)113 259 1999
Fax: +44 (0)113 278 0306
Web: <http://www.bttg.co.uk>
Email: CSLeeds@bttg.co.uk

3.2 Results

Test method and test number	Parameter	No. Tests (specimens)	Results	
			Continuous parameter - mean (m)	Compliance with Class B _{FL} -s1 parameters
BS EN ISO 11925-2:2010	FS (mm)	6	<150mm within 20s	Compliant
	Flaming Droplets / particles		No	Compliant
BS EN ISO 9239-1:2010	Critical Flux (kW/m ²)	3	10.7kW/m ²	Compliant
	Smoke (% min)		99% x min	Compliant

4 Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with BS EN 13501-1:2007+A1:2009.

4.2 Classification

The products Polyflor 2000 PUR / Primus 2000 PUR / Voyager PUR, in relation to their reaction to fire behaviour is classified:

B_{FL}

The additional classification in relation to smoke is:

s1

Fire behaviour	Smoke production	
	B_{FL}	-

Reaction to fire classification: B_{fl} s1

BTTG Testing & Certification Ltd. Registered Office:
Unit 14, Wheel Forge Way, Trafford Park, Manchester M17 1EH
A company registered in England & Wales with company number 04669650. VAT Number GB 816740526
Our laboratories are accredited to EN ISO/IEC 17025



1066

James Halstead France SAS

Parc St Christophe – Pôle Edison 1

95861 Cergy Pontoise - Tel: 08 20 20 32 11

Edition : 05/17 – N°PRIM04128

James Halstead
FLOORING

POLYFLOR
COVERING THE WORLD